

PROVIDED BY CLIENT AND/OR OTHERS



DEDICATED 20 AMP CIRCUIT BREAKER

A designated 20 amp/120 volt primary power electrical circuit must be installed within 5 feet of the proposed sign. The primary power line must originate at your electrical panel and connect to a metal junction box. The junction box must be labeled "Sign". The breaker number must be labeled "Sign" and the breaker number should be noted on the j-box.

*Note: Multiple circuits may be required based on the requirements of the signage.



ASTRONOMICAL TIMER

A 7-day astronomical timer must be installed near the existing electrical panel that is clearly labeled "Sign".



OPTIONAL PROGRAMMABLE TIMER WITH PHOTO CONTROL SWITCH

A photocell must be installed remotely (on roof or near the sign) if the timer is not an astronomical timer. A photocell must be performed by a licensed C-10 electrician as required by the NEC (National Electrical Code), local city, and state regulations. Sunset Signs may be able to provide the above services for additional costs based on field conditions. A photo control switch is not within Sunset Signs scope of work.



MAIN POWER BREAKER PANEL

Main power breaker panel provided by client and/or others. breaker number connected to j-box labeled "Sign".

INSTALLED BY SUNSET SIGNS



POWER SUPPLY & DISCONNECT SWITCH

Sunset signs will provide the power supply(s) and disconnect switch dedicated to your new sign.

QUESTIONS?

Reach out to your project manager directly with any questions or call our main office line for assistance.